

DIESEL FUEL FILL STATION MONITOR

albany
ELECTRICAL SUPPLY CO. INC.
1000 WEST 10TH AVENUE
DENVER, CO 80202
TEL: 303.733.1111
WWW.ALBANYELECTRICAL.COM

ULC
LISTED
COMMERCIAL GRADE
UL 100
UL 100A
UL 100B
UL 100C
UL 100D
UL 100E
UL 100F
UL 100G
UL 100H
UL 100I
UL 100J
UL 100K
UL 100L
UL 100M
UL 100N
UL 100O
UL 100P
UL 100Q
UL 100R
UL 100S
UL 100T
UL 100U
UL 100V
UL 100W
UL 100X
UL 100Y
UL 100Z



INSTRUCTIONS

- Confirm that the "SUPERVISORY POWER ON" white pilot light is illuminated. It confirms that there's 120VAC power to unit.
- Confirm that the "90% HIGH LEVEL STOP FILL" red pilot light **IS NOT ILLUMINATED**. Do not fill if the light is illuminated as tank is already at a high level or float is faulty.
- Toggle the switch to "TEST" to test the alarm horn and the pilot lights. If horn or light does not activate, no filling should occur.
- At "90% HIGH LEVEL STOP FILL", audible and visual alarm activates. Toggle the switch to "SILENCE" to mute the horn.
- Fill procedure is complete.

NOTE : The "90% HIGH LEVEL STOP FILL" red light remains on until the condition is corrected. The alarm circuit resets automatically.

POWER ON



DANGER

DISCONNECT POWER
BEFORE OPENING
ENCLOSURE. THIS MEANS
SHALL BE PROVIDED
BY THE INSTALLER



DANGER

WARNING: High voltage
exists in this enclosure.
Do not touch internal
components unless
you are qualified and
properly trained.
The qualified person must
be notified before
working on the
equipment.



90% HIGH LEVEL
STOP FILL



TEST SILENCE



ULC

LISTED

ULC LISTED
ULC LISTED
ULC LISTED